

Waste oil/Cutting Oil/Waste liquid Reduction
Integrated Low-temperature with No Emission Evaporation

PT CYPRESS WATER TECHNOLOGY

2025 Indonesia

CONTENTS

01 Comparison

04 Case Study

02 Technolgy Brief

05 Equipment Spec

03 Target Markets

01 Technology Comparison



High Temp. MVR

- ◆ Adv: Low Energy consumption
- ◆ Disadv:
 - Steam water quality is poor
 - The heat exchange easily scale
 - The mechanical seal of steam compressor replaced every 3 years.
 - Equipment life time: Short
 - Noise: Loud



Triple-effect Evaporation



- ◆ Adv: High heat transfer rate
- ◆ Disadv:
 - Steam water quality is poor
 - 200~280KWH/ton-waste liquid



Low Temp. Evaporator

- ◆ Adv:
 - Steam water quality is good and reusable.
 - 90~160KWH/ton-waste liquid
 - Equipment life time: >3 years
 - Noise: Low
- ◆ Disadv:
 - The max. capacity is 10 tons per day.

Low Temp. Evaporator with heat pump



Advantage

- No chemical required.
- 35~40°C Evaporation temp.
- Energy recycling of wastewater heating and steam condensation(90~160KWH/ton-waste liquid) .
- Noise: <75dB.
- Low Maintenance cost, No Consumable.
- Fully Automatically operation .


Process

Evaporation Temp

37.6 °C

Vacuum Pressure

-97.052 Kpa



03 Target Markets

◆ Spent electroplating liquid




◆ Waste cutting oil



◆ Waste emulsion oil



◆ Waste Organic Liquid



04 Case Study: Lab test for Reducing Cable industry waste liquid



◆ 100mL Lab test unit



- Test result:**
- ◆ Right: waste liquid, Left: Concentrated
 - ◆ Middle: Condensate
 - ◆ Waste Liquid Reduction Rate: >90%

Waste liquid Source	Cable Industry
Existing treatment	Outsource Treatment
New process	>90% Reduction rate; Condensate water reuseable, <10% Concentrated Outsource Treatment

04 Case Study: Site pilot test results with other equipment:

Reducing Cable Industry Waste Liquid Test Results

Item	HAA0.3	A Equipment	B Equipment
Evaporation temp	37°C	65°C	37°C
Power (KWH/ton-waste liquid)	<150	236.7	Failed
pH of Condensate	7.23	6.65	
COD of Condensate, mg/L	78	230	
Copper of Condensate, mg/L	0.24	3.86	
Petroleum of Condensate, mg/L	0.08	1.17	
Ammonia of Condensate, mg/L	1.22	7.1	
Total Phosphorus of Condensate, mg/L	0.06	0.4	

◆ Pilot test on site: 30days

04 Case Study: Lab Test for Reducing PCB Industry Chemical Tin Waste



◆ 100mL Lab test unit



Test result:

- ◆ Right: Concentrated , Left: Waste liquid
- ◆ Middle: Condensate
- ◆ Waste Liquid Reduction Rate: >85%

Waste liquid Source	Chemical Tin Waste Liquid from PCB Industry
Existing treatment	Outsource Treatment
New process	>85% Reduction rate; Condensate water reuseable <15% Concentrated might be sold based on high Tin %.

05 Case Study: Lab Test for Reducing Waste Oil from Reclaimed Industry



Item	Waste Liquid from Waste Oil Refinery Industry
Waste Liquid	Cond. :8.11ms/cm; PH: 5.7, COD 274 g/L; NH ₃ -N 2100mg/L
Concentrate	COD 1,080g/L; NH ₃ -N 9.3g/L
Condensate	>90%Reduction rate, Cond.:1140 µs/cm ; PH 值5.57, COD 11g/L; NH ₃ -N 347 mg/L

04 Case Study: Suzhou 4m³/D Cutting Waste Oil Project



Waste type	Cutting Waste Oil
Discharge/Month	80~100T
Existing treatment	Outsourcing
New process	>90%Reduction rate, <10%Concentrate Outsourcing

04 Case Study: Wuxi Cable Industry 2m³/D銅拉絲廢液減量:




Waste type	Waste oil
Waste oil source	Waste oil from copper wire drawing processes in the cable industry
Discharge/Month	40~50T
Existing treatment	Outsourcing
New process	>95% Reduction rate, <5% Concentrate, Outsourcing

04 Case Study: Ningbo 2m³/D Waste emulsion oil project



Low-temperature Waste Liquid Tank
Evaporator Concentrated Tank





04 Case Study: Benefit Calculation

Example for emulsion oil reduction :

- 1. Treatment capacity: 500kg per day**
- 2. Outsource cost: 5,000 IDR per kg**
- 3. Power cost: 500IDR per KWH**
- 4. Reduction rate: 90%**
- 5. Saving per day:**

$$500 \times 5.000 - 500 \times (1 - 90\%) \times 5000 - 180 \times 500 \\ = 2.16 \text{ million}$$

Yearly Saving: $330 \times 2.16 \text{ million} = 712.8 \text{ million IDR}$

ROI: $1,120 \text{ million} / 712.8 = 1.6 \text{ year! --} \rightarrow \text{GOOD Investment}$

05 Equipment Specification

ITEM	HAA-0.5	HAA-1.0	HAA-3.0	HAA-8.0	HAA-10
Capacity	0.6m ³ /day	1.0m ³ /day	3m ³ /day	8m ³ /day	10m ³ /day
Operation, hr	24hr/day	24hr/day	24hr/day	24hr/day	24hr/day
Total KW	4.5KW	10KW	21KW	43KW	48KW
Equipment Size	2.1×1.3×2.6m	2.2×1.8×2.6m	2.8×2.4×3m	4.5×2.4×3m	4.5×2.4×3m
Power Consumption	180KWH/m ³	160KWH/m ³	160KWH/m ³	140KWH/m ³	140KWH/m ³

Client Supply compressed air: 50L/min@6kgf/cm²

Welcome to Discussion!

PTCYPRESS WATER TECHNOLOGY

2025 Indonesia